

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3175-1539:114 Page 1 of 1

CATEGORY: Air Filter Units

LISTEE: Filtration Group, Inc., 912 E. Washington St., Joliet, IL 60433
Contact: Joseph Benoit (815) 774-1289 Fax (815) 726-2765

DESIGN: Model "ASHRAE Cell Filters" dry type, throw-away rigid air filters. These filters utilize a ribbon of media folded over separators and mounted into a frame and are manufactured in various sizes with a maximum of 24" x 48" x 12" depth. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Class 1 and 2
Maximum Depth: 12"

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, size, direction of airflow and UL label.

APPROVAL: Listed as Class I and II throw-away air filter units.

11-26-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 17, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**